



SVD Controllers for H_2 -, H_∞ - and μ -optimal Control*

MORTEN HOVD,† RICHARD D. BRAATZ‡ and SIGURD SKOGESTAD†

Key Words—Linear control systems; robust control; large-scale systems; singular-value decomposition; structured singular value; symmetric circulant plants.

Abstract—Plant structure is utilized for the simplification of system analysis and controller synthesis. For plants where the directionality is independent of frequency, the singular-value decomposition (SVD) is used to decouple the system into nominally independent subsystems of lower dimension. In H_2 - and H_∞ -optimal control, the controller synthesis can then be performed for each of these subsystems independently, and the resulting overall SVD controller will be optimal (the same will hold for any norm that is invariant under unitary transformations). In H_∞ -optimal control the resulting controller is also *super-optimal*, since a controller of dimension $n \times n$ will minimize the norm in n directions. For robust control in terms of the structured singular value μ , the SVD controller is optimal for a practically relevant class of block-diagonal structures and uncertainty and performance weights. © 1997 Elsevier Science Ltd.

Nomenclature

- D block-diagonal scaling matrix;
- F_i lower linear fractional transformation (see (5));
- $G(s) = U\Sigma_G(s)V^H$: transfer-function matrix for the plant;
- $K(s)$ transfer-function matrix for the controller;
- $M(s)$ matrix whose norm is to be minimized in the controller synthesis;
- $M_0(s)$ matrix $M(s)$ with the weights removed;
- n plant dimension ($n \times n$);
- $N(s)$ interconnection matrix for the synthesis problem;
- R 'real Fourier matrix'; real, unitary eigenvector matrix for symmetric circulant matrices;
- s Laplace variable;
- U output singular vector matrix of the plant $G(s)$;
- U_{O_i} output singular vector matrix for output weight i ;
- V input singular vector matrix of the plant $G(s)$;
- V_{I_i} input singular vector matrix for input weight i ;
- $W_1(s) = \text{diag}\{W_{1i}(s)\}$: block-diagonal matrix of weights for the inputs to $M(s)$;
- $W_0(s) = \text{diag}\{W_{2i}(s)\}$: block-diagonal matrix of weights for the outputs from $M(s)$;
- Δ block-diagonal matrix of perturbations;
- Δ_i i th block on the diagonal of Δ (of the same size as $G(s)$);
- μ structured singular value;
- σ singular value;
- $\bar{\sigma}$ largest singular value;
- $\Sigma(s)$ matrix of singular values;
- ω frequency.

* Received 23 January 1995; revised 23 April 1996; received in final form 21 August 1996. This paper was not presented at any IFAC meeting. This paper was recommended for publication in revised form by Associate Editor I. Petersen under the direction of Editor Ruth F. Curtain. Corresponding author Professor S. Skogestad. Tel. +47 7359 4154; Fax +47 7359 4080; E-mail skoge@kjemi.unit.no.

† Chemical Engineering, Norwegian University of Science and Technology, N-7034 Trondheim, Norway.

‡ Department of Chemical Engineering, University of Illinois at Urbana-Champaign, 600 South Mathews Avenue, Box C-3, Urbana, IL 61801, U.S.A.

Subscripts

- I input to synthesis problem;
- O output from synthesis problem;
- i block i on the diagonal of a block-diagonal matrix,
- j singular value j .

Superscripts

- H Hermitian (complex-conjugate transpose); denotes that the matrix has been transformed by pre- and postmultiplication with unitary matrices.

1. Introduction

In this paper we study SVD controllers, which we define to have the form

$$K(s) = V\Sigma_K(s)U^H, \quad (1)$$

where $\Sigma_K(s)$ is a diagonal matrix with real rational transfer functions on the diagonal, and U and V are real unitary (e.g. orthogonal) singular vector matrices that are derived from a singular-value decomposition (SVD) of the plant $G(s)$. Here H indicates the Hermitian (complex conjugate transpose), which for real matrices is equal to the transpose, i.e. $U^H = U^T$.

SVD controllers have been studied previously by Hung and MacFarlane (1982) and Lau *et al.* (1985). In both these references the SVD structure is essentially used to counteract interactions at one given frequency, since the problems considered are such that U and V change with frequency. However, in this paper we consider a class of problems for which U and V are constant at all frequencies and can be chosen to be real. Restricting our attention to these cases allows us to address the optimality of the SVD controller for H_2 -, H_∞ - and μ -optimal control. To be more specific, we consider plants $G(s)$ of dimension $n \times n$ that can be decomposed into

$$G(s) = U\Sigma_G(s)V^H, \quad \Sigma_G(s) = \text{diag}\{\sigma_{G_i}(s)\}, \quad (2)$$

where the output and input rotation matrices U and V are constant real unitary matrices, and $\Sigma_G(s)$ is a diagonal matrix with real rational transfer functions on the diagonal. The requirement for $\Sigma_G(s)$ to have rational transfer-function elements arises because we use state-space-based controller synthesis methods, and need the elements to be realizable. Restricting U and V to be real implies that the controller $K(s)$ will always be realizable, provided that $\Sigma_K(s)$ is realizable.

Equation (2) is the singular-value decomposition of the plant $G(s)$, with the slight modification that the diagonal elements of $\Sigma_G(s)$, which we shall refer to as *singular values*, have *phase*, and without necessarily requiring that the singular values in $\Sigma_G(s)$ are ordered according to their magnitudes. At a given frequency, any transfer function can be decomposed into its singular-value decomposition, but we are here assuming that the rotation matrices U and V are independent of frequency. In this case the singular-value decomposition can be used to decompose the plant into n 'subplants' $\sigma_{G_i}(s)$ (the diagonal elements of $\Sigma_G(s)$). To simplify the presentation, in this paper we consider only SISO subplants, but it is straightforward to generalize the

results to cases where unitary transformations decompose the plant into MIMO subplants; that is, $\Sigma_G(s)$ is block-diagonal (for details see Hovd and Skogestad, 1994a).

The two main contributions of this paper are to show that, under certain mild conditions on the control problem weights, there exists an optimal SVD controller for a plant of the form in (2), and that the controller design can be simplified for such problems. The basis for these results is that the H_2 and H_∞ norms

$$\|M(s)\|_2 \equiv \sqrt{\frac{1}{2\pi} \int_{-\infty}^{\infty} \text{Trace}[M^H(j\omega)M(j\omega)] d\omega},$$

$$\|M(s)\|_\infty \equiv \sup_{\omega} \bar{\sigma}(M(j\omega))$$

are invariant under unitary scalings. To make use of this property, we must have that not only the plant but the control problem as a whole (including the weights) can be 'diagonalized' by unitary matrices. For the diagonalized problem we show that there exists a diagonal controller that is optimal, from which an optimal SVD controller for the original problem can be constructed. Furthermore, controller design is simplified, since the elements of the diagonal controller can be obtained by performing controller synthesis on n independent subsystems involving $\Sigma_G(s)$. We show that in the H_∞ case the resulting controller is *super-optimal*, since the norm is minimized in the worst direction for each of these subsystems.

These results have not to our knowledge been presented before in the literature, at least not in this general form. This is somewhat surprising, since plants of the form in (2) are common in practical applications. This paper extends the results of Hovd and Skogestad (1994a), by proving that, under certain conditions, an SVD controller is optimal when we consider robust H_∞ performance (i.e. μ -optimal control) and have model uncertainty, which allows for plants that may not be of the form in (2) (although the nominal plant is of this form). In particular, we find that, with some mild conditions on the weights, the results hold for any combination of full-block (unstructured) and repeated diagonal complex uncertainty.

2. Examples of plants described by SVD

In this section we provide examples of plants that can be expressed in the form given in (2). The multivariable directionality of these plants, as expressed by the two singular vector matrices U and V , does not change with frequency, and U and V are real. The following two classes of plants are of special interest in applications:

A. Plants with scalar dynamics multiplied by a constant matrix. Let

$$G(s) = k(s)A, \quad (3)$$

where A is a constant real matrix. Plant models of this form occur frequently in practice, at least in the chemical process industries, where the control engineer often chooses to work with very crude models.

B. Symmetric circulant plants. Plants with symmetric circulant transfer matrices are common in practice, and include a large number of processes with some symmetric spatial arrangement. Examples include paper machines where edge effects are neglected (Laughlin *et al.*, 1993; Wilhelm and Fjeld, 1983), dies for plastic films (Martino, 1991), and multizone crystal growth furnaces (Abraham and Lunze, 1991). In general, all symmetric circulant matrices can be diagonalized by the same unitary matrix; that is

$$C(s) = R^T \Lambda_C(s) R, \quad (4)$$

where R is the real Fourier matrix (for details see Hovd and Skogestad, 1994a). This is of the form in (2), with $U = V = R^T$.

A subset of circulant symmetric matrices are called *parallel* matrices, and are described by $P = aI + bE$, where I is the identity matrix, E is a matrix with each element equal to one, and a and b are real scalars. Parallel transfer function

matrices occur frequently in the process industries, and arise whenever there are identical units in parallel that interact with each other. Examples are found in distribution networks, when there are parallel units (e.g. reactors, compressors, pumps and heat exchangers) in a chemical plant (Shinsky, 1979, 1984; Hovd and Skogestad, 1994a), in electric power systems (Lunze, 1986, 1991), in adhesive coating processes (Braatz *et al.*, 1992) and in communication between ships (Hazewinkel and Martin, 1983).

Remark. The set of plants given by (2) is more general than the two classes A and B given above, since the first class only includes plants for which the diagonal elements of $\Sigma_G(s)$ have the same dynamic behavior, and the second class only includes plants for which $U = V$.

3. SVD control problem

In this section we consider plants that can be decomposed into $G(s) = U\Sigma_G(s)V^H$ (as shown in (2)), and define more exactly the class of control problems covered by the results of this paper. For a general control problem, $M(s)$ is the closed-loop transfer function between external input signals (e.g. disturbances, noise and references) and external output signals (e.g. control error and error signals), which we want to keep small. The closed-loop transfer function $M(s)$ depends on the controller $K(s)$, and the controller synthesis problem is to minimize $\|M\|$ over the set of all stabilizing controllers K . Typical choices of norm include the H_2 and the H_∞ norms (this is generalized to the structural singular value for the case with model uncertainty). The general class of *SVD problems* covered by the results of this paper are described below.

Definition 1. (SVD problem.) Consider an $n \times n$ plant $G(s) = U\Sigma_G(s)V^H$, where U and V are real orthogonal matrices and $\Sigma_G(s)$ is a diagonal transfer-function matrix. Consider a control problem where the objective is to design a feedback controller $K(s)$ that minimizes a unitary invariant norm of

$$M(s) = W_O(s)M_0(s)W_I(s),$$

where

$$M(s) = F_I(N(s), K(s)) \\ = N_{11}(s) + N_{12}(s)K(s)[I - N_{22}(s)K(s)]^{-1}N_{21}(s). \quad (5)$$

The *interconnection matrix* $N(s)$ is a function of the plant model and the weights, but is independent of the controller K .

The weighting matrices $W_O(s)$ and $W_I(s)$ are defined to be block-diagonal, with each block having dimensions compatible with the dimensions of the subblocks containing $G(s)$ and $K(s)$ in $M_0(s)$:

$$W_O(s) = \text{diag}\{W_{O_i}(s)\}, \quad W_{O_i}(s) = U_{O_i}\Sigma_{W_{O_i}}(s)V_{O_i}^H, \\ W_I(s) = \text{diag}\{W_{I_i}(s)\}, \quad W_{I_i}(s) = U_{I_i}\Sigma_{W_{I_i}}(s)V_{I_i}^H,$$

with V_{O_i} and U_{I_i} satisfying

- $V_{O_i} = U$ when $W_{O_i}(s)$ premultiplies $G(s)$ in subblocks of $M_0(s)$;
- $V_{O_i} = V$ when $W_{O_i}(s)$ premultiplies $K(s)$ in subblocks of $M_0(s)$;
- $U_{I_i} = V$ when $W_{I_i}(s)$ postmultiplies $G(s)$ in subblocks of $M_0(s)$;
- $U_{I_i} = U$ when $W_{I_i}(s)$ postmultiplies $K(s)$ in subblocks of $M_0(s)$.

In the above definition the terms 'premultiply' and 'postmultiply' are used in a general sense; for instance, in the formula $W_O(I + GK)^{-1}W_I$ the weight W_O premultiplies G and W_I postmultiplies K . There are no requirements on the other matrices in the weights, other than U_{O_i} and V_{I_i} being unitary and $\Sigma_{W_{O_i}}(s)$ and $\Sigma_{W_{I_i}}(s)$ being diagonal.

Remark 1. The definition of an SVD control problem may seem restrictive and complicated, but the conditions on the

weights are satisfied for most problems with a plant of the form $G(s) = U\Sigma_G(s)V^H$.

Remark 2. Essentially, the weights must be consistent with the plant $G(s)$, such that, after substituting $G(s) = U\Sigma_G(s)V^H$ and $K(s) = V\Sigma_K(s)U^H$ into $M_0(s)$, the unitary matrices U and V are cancelled by the weights when forming $M(s)$, in the sense that we can write $M(s) = U_0\tilde{M}(s)V_0^H$, where all the blocks of $\tilde{M}(s)$ are diagonal. A similar transformation may be used to obtain a block-diagonal $\tilde{N}(s)$, but, since $N(s)$ is independent of the controller, we do not need to assume an SVD controller to achieve this. This is important when proving that the SVD controller is actually optimal (see the next section).

Remark 3. Scalar-times-identity weights $W_i(s) = w_i(s)I$ always satisfy the conditions of an SVD problem, since $w_i(s)I = U w_i(s)U^H = V w_i(s)V^H$.

4. H_2 - and H_∞ -optimal control

For an SVD problem, $N(s)$ will be such that there exist block-diagonal unitary matrices

$$U_w = \text{diag}\{\text{diag}\{U_{O_i}\}, U\}, \quad V_w = \text{diag}\{\text{diag}\{V_{I_i}\}, V\} \quad (6)$$

such that

$$\tilde{N}(s) = U_w^H N(s) V_w \quad (7)$$

is a matrix consisting of diagonal subblocks. The rows and columns of $\tilde{N}(s)$ can be rearranged to give a block-diagonal matrix, for which an optimal controller \tilde{K} can be constructed by solving n SISO independent optimal controller synthesis problems for each subblock (this is proved in Hovd *et al.*, 1996). An optimal SVD controller for the original N is constructed from $K = V\tilde{K}U^H$. The result also applies to any other norm that is invariant under unitary transformations.

Theorem 1. (H_2 - and H_∞ -optimality.) Consider an SVD problem (Definition 1). Then

- (i) There exists an SVD controller that is H_2 (H_∞)-optimal.
- (ii) The optimal controller can be computed by designing n independent SISO H_2 (H_∞)-optimal controllers, one for each of the SISO subplants of the plant.
- (iii) For H_∞ -optimal control, this controller is super-optimal; that is, the H_∞ objective is optimized in n directions.

Proof. See Hovd *et al.* (1996) for a detailed proof and Hovd and Skogestad (1994a) for a more general but less detailed proof. \square

Remark 1. The number of states of the controller computed via Theorem 1 is equal to the number of states of a controller based on regular H_∞ synthesis (Hovd *et al.*, 1996). That is, for this class of problems, super-optimality does not require a controller with a higher number of states.

Remark 2. In general, we solve n independent synthesis subproblems of low dimension. In some cases the problem is even further reduced in size, since some of these subproblems are identical. For example, for the case of symmetric circulant systems we need only solve $\frac{1}{2}(n+1)$ SISO problems for odd n and $\frac{1}{2}n+1$ problem for even n . In the case of parallel processes we need only solve two independent subproblems (since $n-1$ subproblems are identical). For details see Hovd and Skogestad (1994a).

Remark 3. The theorem may be generalized to cases where the subplants $\sigma_{G_i}(s)$ are matrices. For example, see Hovd and Skogestad (1994a), which considered the special case of symmetric circulant plants.

5. μ -optimal control

In this section we shall generalize the H_∞ problem studied above to the design of robust optimal controllers. This

control problem results when we introduce model uncertainty and want to minimize the H_∞ norm for robust performance, or alternatively want to optimize robust stability.

5.1. *The structured singular value.* The structured singular value μ takes uncertainty in a feedback system explicitly into account. Readers not familiar with the structured singular value are referred to Doyle (1982); only a very brief introduction will be given here. The uncertainties in the system are modeled with H_∞ norm-bounded perturbation blocks with weights to normalize the maximum singular value of each perturbation block to unity. The block diagram for the feedback system is then rearranged to give an interconnection matrix $M(s)$ and a block-diagonal matrix Δ with the perturbation blocks along the diagonal (see Fig. 1). If Δ is a full matrix (i.e. Δ has no structure), the controller synthesis problem is a H_∞ problem, and is covered by the results of the previous section. Otherwise, the structured singular value is needed to account for the uncertainty in a nonconservative manner.

The structured singular value with respect to the uncertainty structure Δ is defined as

$$\mu(M) \equiv \begin{cases} 0 & \text{if there does not exist } \Delta \text{ such} \\ & \text{that } \det(I + M\Delta) = 0, \\ \left[\min_{\Delta} \{\bar{\sigma}(\Delta) \mid \det(I + M\Delta) = 0\} \right]^{-1} & \text{otherwise.} \end{cases} \quad (8)$$

Currently no simple computational method exists for exactly calculating μ in general, and recent work suggests that an efficient exact method is most likely not possible (Braatz *et al.*, 1994). This motivates the common practice, which is to compute instead the upper bound

$$\mu(M) \leq \inf_D \bar{\sigma}(DMD^{-1}), \quad (9)$$

where D is an invertible matrix with a structure such that $D^{-1}\Delta D = \Delta$. For example, $D = dI$ if Δ is a full matrix, and D is a full matrix if Δ is repeated-diagonal ($\Delta = \delta I$). For complex uncertainties the upper bound (9) is equal to μ for three or fewer full blocks (Doyle, 1982), and usually within 1–2% when there are no repeated blocks (Balas *et al.*, 1991). A controller that minimizes the upper bound for μ in (9) will be said to be DMD^{-1} -optimal.

Another reason for using the upper bound is that the goal of the most popular procedure for designing robust controllers, called DK iteration, is to minimize the upper bound. Also, when all the uncertainties are full and complex, the upper bound is a necessary and sufficient condition for robustness to *arbitrarily slow time-varying linear uncertainty* (for details see Poolla and Tikku, 1995). It can be argued that this uncertainty description may be more useful for practical control problems.

The standard DK-iteration procedure (Doyle and Chu, 1985) attempts to find the DMD^{-1} -optimal controller. DK iteration involves alternating between the following two steps until the upper bound is no longer minimized.

D Step. Find $D(s)$ to minimize frequency-by-frequency the upper bound on μ in (9).

K Step. Scale the controller design problem with $D(s)$, and design an H_∞ -optimal controller for the scaled design problem DMD^{-1} .

Although convergence to the global optimum is not guaranteed, DK iteration appears to work well for processes of low dimensionality (Doyle and Chu, 1985).




Fig. 1. Equivalent representations of system M with perturbation Δ .

5.2. *Structure of the uncertainty.* It is important to note that Δ often has two levels of structure. First, Δ is often composed of subblocks Δ_i of the same size as G :

$$\Delta = \text{diag} \{ \Delta_i \}. \tag{10}$$

These subblocks may represent different sources of uncertainty in the system. For example, actuator uncertainty is located at the input of the plant, and is commonly modeled as multiplicative input uncertainty, i.e. $\Delta_i = \Delta_r$. Second, each subblock Δ_i may have structure to reduce conservatism. For example, actuators may not influence each other, so uncertainty associated with these actuators would be described by a diagonal Δ_i . The most common (and useful) structures for the subblocks Δ_i are

- full block uncertainty, where Δ_i is a full matrix;
- independent diagonal uncertainty, $\Delta_i = \text{diag} \{ \delta_{ij} \}$, $j = 1, \dots, n$, is a diagonal matrix,
- repeated diagonal uncertainty, where $\Delta_i = \delta_i I$, i.e. a scalar uncertainty δ_i multiplied with an identity matrix.

5.3. *μ -optimality of SVD controllers.* The uncertainty weights must satisfy certain conditions to ensure μ -optimality of the SVD controllers.

Definition 2: Robust SVD problems. Consider an SVD problem with $M(s) = W_O(s)M_0(s)W_I(s)$ as in Definition 1, and multiple sources of uncertainty $\Delta = \text{diag} \{ \Delta_i \}$, as illustrated in Fig. 1. In addition to the requirements of Definition 1 the weights $W_{O_i} = U_{O_i} \Sigma_{W_{O_i}}(s) V_{O_i}^H(s)$ and $W_{I_i} = U_{I_i} \Sigma_{W_{I_i}}(s) V_{I_i}^H(s)$ related to each Δ_i should fulfill the following:

- (i) $U_{O_i} = V_{I_i}$ for all repeated diagonal uncertainty, $\Delta_i = \delta_i I$;
- (ii) $U_{O_i} = V_{I_i} = I$ for all independent diagonal uncertainty, $\Delta_i = \text{diag} \{ \delta_{ik} \}$, $k = 1, \dots, n$.

Remark 1. For a ‘full’ (unstructured) uncertainty block Δ_i no further requirements on the weights are needed.

Remark 2. Requirement (i) for repeated diagonal blocks holds regardless of the uncertainty’s location when the plant is described by a normal transfer-function matrix (e.g. symmetric circulant plants) and the weights are repeated-diagonal.

Remark 3. Requirement (ii) on the weights for independent diagonal uncertainty is very restrictive. For example, it allows for scalar-times-identity weights only for cases when U or V are equal to the identity matrix (that is, the inputs or outputs to the plant are naturally aligned in the direction of the singular values).

Now we show that for this class of problems the interconnection matrix N can be pre- and postmultiplied by block-diagonal unitary matrices to arrive at an equivalent interconnection matrix \tilde{N} consisting of diagonal subblocks.

Lemma 1. Let \tilde{N} be defined as in (6) and (7). For μ -optimality and DMD^{-1} -optimality of robust SVD problems (Definition 2), the ‘diagonalized’ control problem is equivalent to the original problem, in the sense that

$$\min_K \mu(F_I(N, K)) = \min_{\tilde{K}} \mu(F_I(\tilde{N}, \tilde{K})), \tag{11}$$

$$\min_{K, D} \inf [DF_I(N, K)D^{-1}] = \min_{\tilde{K}, \tilde{D}} \inf [DF_I(\tilde{N}, \tilde{K})\tilde{D}^{-1}], \tag{12}$$

where both μ problems are with respect to the uncertainty in the original control problem, and the structure of the D matrices in both DMD^{-1} problems is compatible with this uncertainty.

Proof. In the block diagram for the system, replace G with $U \Sigma_G(s) V^H$, and substitute in the weights $W_{I_i}(s)$ and $W_{O_i}(s)$. Rearranging the block diagram (see Fig. 1) gives \tilde{N} with

diagonal subblocks, with the subblocks of $\tilde{\Delta}$ given by $\tilde{\Delta}_i = V_{I_i}^H \Delta_i U_{O_i}$. Note that, under the assumptions on U_{O_i} and V_{I_i} in Definition 2,

- (i) $\tilde{\Delta}_i$ is full if and only if Δ_i is full;
- (ii) $\tilde{\Delta}_i$ is repeated-diagonal if and only if Δ_i is repeated-diagonal;
- (iii) $\tilde{\Delta}_i$ is independent-diagonal if and only if Δ_i is independent-diagonal.

Thus in Fig. 1 the middle block diagram is equivalent to the rightmost block diagram.

A similar argument holds with regard to the upper bound of μ . Under the assumptions on U_{I_i} and V_{O_i} , for each diagonal or full block Δ_i the corresponding D_i and its inverse commute with U_{I_i} and V_{O_i} . For repeated diagonal blocks the U_{I_i} and V_{O_i} can be absorbed into the D_i . \square

The following results on the optimality of the SVD controller follow from Theorem 1 and Lemma 1.

Theorem 2. (DMD⁻¹-optimality). Consider an SVD problem where the objective is to minimize $\sup_{\omega} \min_D \|DMD^{-1}\|_{\infty}$, where $D^{-1} \Delta D = \Delta$. Assume that all uncertainty blocks Δ_i are full blocks. Then

- (i) there exists an SVD controller that is optimal;
- (ii) if DK iteration is used to obtain the optimal controller, the K step (with fixed D) consists of n independent SISO H_{∞} -optimal control problems, one for each of the SISO subplants σ_{G_i} of $G(s)$.

Proof. Let N denote the interconnection matrix corresponding to M , where N has a block structure corresponding to the uncertainties Δ_i . With fixed D scales, we may absorb D and D^{-1} into N to get

$$N_D = \hat{D} N \hat{D}^{-1}, \quad \hat{D} = \text{diag} \{ D, I \}.$$

We are then left with an H_{∞} problem in terms of N_D . Since all uncertainty blocks Δ_i are full, the D scales are of the form $D = \text{diag} \{ D_i \}$, $D_i = d_i I_i$. Then the only difference between N and N_D will be that of the off-diagonal blocks are multiplied by scalars. Thus the structure of each block in N_D will be the same as in N , and we can use the transformation $\tilde{N}_D(s) = U_W^H N(s) V_W$ to obtain an \tilde{N}_D with diagonal blocks. Subsequent permutations yield a block-diagonal \tilde{N}_D . This implies that for a fixed D there exists an optimal SVD controller that can be obtained by solving n independent SISO H_{∞} problems. Since an SVD controller is optimal for any fixed D , this structure must also be optimal for the optimal D . \square

Theorem 3. (μ -optimality.) Consider a robust SVD problem where the objective is to minimize $\sup_{\omega} \mu(M)$. Assume that all uncertainty blocks Δ_i are diagonal (repeated or independent) except possibly one full block. Then

- (i) there exists an SVD controller that is optimal;
- (ii) the μ -optimal control problem decouples into n independent SISO μ -optimal control problems, one for each of the SISO subplants of the plant.
- (iii) For the case in which one of the uncertainties is a full block, the full block can be replaced by a diagonal (repeated or independent) block without affecting the value of the μ objective.

Proof. If all uncertainty blocks Δ_i are diagonal (including repeated diagonal uncertainty) then the system consists of independent subsystems. If one uncertainty block is full then the diagonal uncertainty blocks can be absorbed into the interconnection matrix to get a ‘reduced’ \tilde{N} that still consists of diagonal subblocks after absorbing the diagonal uncertainty blocks. Whatever the values of the diagonal blocks, Theorem 1 implies that an SVD controller is optimal for this ‘reduced’ control problem. Thus an SVD controller is optimal for the original μ problem. Since the M matrix for

the 'reduced' control problem is diagonal, the full-block uncertainty block can be replaced with repeated scalar blocks without affecting the value of the worst-case performance objective. Hence all of the uncertainty can be taken to be diagonal, and the μ -optimal control problem decouples into n independent SISO μ -optimal control problems. \square

The above results complement each other in that Theorem 2 handles one form of uncertainty (full) and Theorem 3 handles the other (diagonal). Both types of uncertainty can be handled by assuming that μ is equal to its upper bound.

Theorem 4. (μ and DMD⁻¹ optimality.) Consider a robust SVD control problem (Definition 2), and assume that μ is equal to its upper bound (9). Then

- (i) there exists an SVD controller that is μ -optimal;
- (ii) for the DK iteration procedure, the K step consists of n independent SISO H_∞ -optimal control problems, one for each of the SISO subplants of the plant;
- (iii) for repeated diagonal uncertainty, D_i can be taken to be diagonal rather than full in the D step.

Proof. All diagonal blocks (repeated or independent) can be absorbed into the interconnection matrix \tilde{N} without changing its structure. By Theorem 2 an SVD controller is optimal for this 'reduced' control problem for all values of the diagonal blocks. Thus an SVD controller is optimal for the original μ problem.

For independent-diagonal and full-block Δ_i , D_i is diagonal and cannot induce interaction between individual subproblems. This also holds for D_i corresponding to repeated-diagonal $\Delta_i = \delta_i I$. To see this, again consider the 'reduced' control problem. If the D_i corresponding to the repeated diagonal blocks introduced interaction between subproblems, they would effectively allow for a larger class of uncertainty than the original uncertainty description.

Scalings D_i that do not cause interactions between subproblems are parameterized by unitary-times-diagonal matrices. The unitary matrices do not affect the value of the H_∞ norm, so can be ignored. \square

The assumption that μ is equal to its upper bound is not restrictive (see Section 5.1).

Theorems 1–4 state that there exists an optimal SVD controller for classes of problems of engineering interest. Hovd *et al.* (1996) consider other classes of problems for which an SVD controller may not be optimal, but where a substantial simplification in system analysis and controller synthesis results in selecting the controller to be of SVD form. In particular, conditions are given on the weights and

Table 1. Algorithm for μ -optimal SVD controllers using DK iteration

1. Test whether the problem is a robust SVD problem as given by Definitions 1 and 2. If the structure of an uncertainty Δ_i and its corresponding weights $W_i(s)$ do not satisfy Definition 2, then an SVD controller may not be optimal. To use the design procedure, treat the uncertainty as a full block, realizing that this is potentially conservative.
2. Form $\tilde{N}(s)$ as given by (7) and rearrange it such that it is block-diagonal.
3. Delete all identical subproblems in \tilde{N} .
4. K step. Design an H_∞ -optimal controller for each independent unique subproblem, and collect the optimal $\tilde{K}_i(s)$ (without repetitions) into a diagonal matrix.
5. D step: Calculate the tight upper bound on μ in (9) and obtain $D(s)$. Return to Step 4 until DK iteration converges.
6. Collect the optimal $\tilde{K}_i(s)$ (including repetitions for identical subproblems) into a diagonal matrix $\Sigma_K(s)$. Form $K(s) = V \Sigma_K(s) U^H$.
7. If the DK-iteration procedure converged to the global minimum then this would be the μ -optimal controller under the assumptions of Theorem 4, for the uncertainty assumed in Step 1 of this algorithm.

on the source of uncertainty for which an H_∞ -optimal controller is μ -optimal irrespective of the structure of the uncertainty block.

5.4. DK iteration: reduction of computational effort. The above results can be used to reduce the computational effort involved in the K step of the DK-iteration procedure in two ways. First, instead of solving one large H_∞ -synthesis problem, one may solve n smaller H_∞ -synthesis subproblems. Second, some of these n subproblems may be repeated (identical); for example, this occurs for the important case when both the plant and weights are symmetric circulant (or parallel). In general, the computational effort is *not* reduced in the D step where the upper bound to μ is computed, since for the case of full block uncertainty we have $D = dI$, so d should be the same for all subproblems. This restriction is difficult to incorporate unless a simultaneous approach is used. However, all repeated subproblems need only be considered once in computing the D_i (see (iii) in Theorem 4). Thus repeated subproblems can be deleted before starting the DK-iteration design procedure, and for a large number of subsystems the size of the DK-iteration and μ -analysis problems can be reduced dramatically.

When all uncertainty blocks are diagonal except possibly one full block, and the weights for the diagonal blocks satisfy Definition 2, the subproblems can be considered independently for the D step, since the D_i corresponding to the full block can be normalized to be the identity matrix. The general DK-iteration procedure for designing SVD controller for SVD problems is summarized in Table 1. Performing DK iteration on the transformed system will converge faster and is numerically better conditioned than on the original system. This is both because the H_∞ subproblems are smaller than the original problem, and because the algorithm will be initialized with a controller that has the correct (optimal) directionality. This will be illustrated in the examples.

6. Examples

The following examples illustrate the computational usefulness of the results of this paper.

Example 1: Distillation column. Consider the robust controller design problem for the simplified distillation column introduced by Skogestad *et al.* (1988), which has been used as a benchmark problem for comparing methods for robust controller design (Freudenberg, 1989; Chen and Freudenberg, 1990; Yaniv and Barlev, 1990; Limebeer, 1991; Lundström *et al.*, 1991; Lin, 1992). Theorem 4 implies that (at least for the case with full block uncertainty) there exists an SVD controller that is μ -optimal for this design problem (for details see Hovd *et al.*, 1996). This knowledge can be used to design an SVD controller that is nearly μ -optimal that has only four states (Hovd *et al.*, 1996).

Example 2: Parallel reactors with combined precooling. A simplified model $G(s)$ of four parallel reactors with combined precooling (Skogestad *et al.*, 1989) is

$$G(s) = \frac{1}{100s + 1} \begin{bmatrix} 1 & 0.7 & 0.7 & 0.7 \\ 0.7 & 1 & 0.7 & 0.7 \\ 0.7 & 0.7 & 1 & 0.7 \\ 0.7 & 0.7 & 0.7 & 1 \end{bmatrix} \quad (13)$$

The real Fourier matrix diagonalizes the plant (Hovd *et al.*, 1996); that is, $G(s) = R^H \Sigma_G(s) R$, where the plant singular values are

$$\sigma_{G1}(s) = \frac{3.1}{100s + 1},$$

$$\sigma_{G2}(s) = \sigma_{G3}(s) = \sigma_{G4}(s) = \frac{0.3}{100s + 1}.$$

Consider the process with input and output uncertainty as shown in Fig. 2. The input uncertainty Δ_1 and output




Fig. 2. Block diagram for plant with uncertainties in Example 2.

uncertainty Δ_2 are both assumed to be independent-diagonal, with uncertainty weights $W_1(s) = \text{diag}\{0.2(5s+1)/(0.5s+1)\}$ and $W_2(s) = \text{diag}\{0.2(2.5s+1)/(0.25s+1)\}$. To reject disturbances at the plant output, we include the performance specification $\bar{\sigma}(W_3S_p) < 1 \forall \omega$, with $W_3(s) = \text{diag}\{0.5(10s+1)/10s\}$. The overall problem (before SVD reduction) has two diagonal 4×4 uncertainty blocks and one full 4×4 performance block, and we get a 12×12 interconnection matrix:

$$M = \begin{bmatrix} -W_1KG(I+KG)^{-1} & -W_1K(I+GK)^{-1} \\ W_2G(I+KG)^{-1} & -W_2GK(I+GK)^{-1} \\ -W_3G(I+KG)^{-1} & -W_3(I+GK)^{-1} \\ & W_1K(I+GK)^{-1} \\ & \times W_2GK(I+GK)^{-1} \\ & W_3(I+GK)^{-1} \end{bmatrix}. \quad (14)$$

In order to make this a robust SVD problem (see Definition 2), we need to assume that all the uncertainty blocks are full. Then there are three full blocks and μ is equal to its upper bound. Theorem 4 implies that there exists an SVD controller that is μ -optimal for this potentially conservative case. In addition, three of the four subproblems in \tilde{N} are identical in the algorithm for μ -optimal SVD controllers (Table 1). Thus in DK iteration we may solve two 3×3 independent H_∞ problems in the K step, and obtain the scalings $d_1(s)$ and $d_2(s)$ from a 6×6 matrix M in the D step. Using this procedure, we were able to find a controller resulting in a μ value of 0.93. For brevity, the state space representation of the eigenvalues of this controller is given elsewhere (Hovd *et al.*, 1996).

Thereafter we attempted to use DK iteration to improve the controller design by using the true diagonal structure for the uncertainties Δ_1 and Δ_2 , the original 12×12 interconnection matrix (14), and the above controller as a starting point. However, we found that this increased the complexity of the controller synthesis problem so much that we were unable to improve the design using DK iteration. The best controller the software was able to obtain had a μ value of 0.96, which is larger than the μ value for the controller the algorithm was initialized with. This result shows that there are numerical inaccuracies with the off-the-shelf software. It also demonstrates the important advantage of reduced problem size that results from applying our method.

7. Discussion

The SVD structure can be used for designing controllers with a low number of states. Using V as a precompensator and U^H as a postcompensator, we are left with n SISO controllers to design for a plant of dimension $n \times n$. This design problem is similar to the conventional decentralized control problem (e.g. Hovd and Skogestad, 1994b), and may be solved by sequential design, independent design or simultaneous design (parameter optimization). The last approach was used in Example 1.

Several authors have proposed to design controllers with the SVD structure based on the SVD of the plant at some important frequency (Lau *et al.*, 1985; Hung and MacFarlane, 1982). The results of this paper imply that the SVD structure is optimal at that fixed frequency (with some restrictions on the structures of the perturbation blocks given in Definition 2), thus providing a theoretical justification for such design procedures. These design methods should perform well for process control problems that do not have U and V varying rapidly as a function frequency, but may perform poorly for other processes such as flexible structures.

A simple lower bound on the achievable value for the upper bound to μ can be computed by applying the algorithm to minimize the upper bound at each frequency (Lee *et al.*, 1995). Because each design subproblem at a fixed frequency only involves finding one complex scalar, the synthesis part is very simple (the state-space algorithm need not be used). This frequency-by-frequency approach will not yield a realizable controller, since issues such as causality and phase-gain relationships are ignored. However, this is a valid lower bound on the achievable performance by a realizable

controller, and can be a useful controllability measure (Lee *et al.*, 1995).

The results of this paper are easily generalized to cases with multivariable, possibly nonsquare subplants. Synthesis problems similar to class B in Section 2 arise naturally whenever identical multivariable plants are arranged in parallel or in a symmetric manner.

8. Conclusions

For plants where the directionality is independent of frequency, the singular-value decomposition (SVD) is used to decouple the system into nominally independent subsystems of lower dimension. In H_2 - and H_∞ -optimal control, the controller synthesis can then be performed for each of these subsystems independently, and the resulting overall SVD controller will be optimal (the same will hold for any norm that is invariant under unitary transformations). In H_∞ -optimal control the resulting controller is also *super-optimal*, since a controller of dimension $n \times n$ will minimize the norm in n directions.

For robust control in terms of the structured singular value μ , the SVD controller is optimal for a wide class of systems with full-block and repeated-diagonal complex uncertainty. Substantial computational savings can be achieved in the controller synthesis step of the DK -iteration scheme. The results of this paper provide a theoretical justification of controller synthesis methods proposed by other authors. Other applications of the SVD controller were described, including its use for low-order controller design, and in efficiently computing controllability measures.

An extended version of this paper is available as a technical report (Hovd *et al.*, 1996).

References

- Abraham, R. and J. Lunze (1991). Modelling and decentralized control of a multizone crystal growth furnace. In *Proc. European Control Conf.*, Grenoble, France, pp. 2534–2539.
- Balas, G. J., J. C. Doyle, K. Glover, A. Packard and R. Smith (1991). *μ -Analysis and Synthesis Toolbox User's Guide*. MUSYN Inc., Minneapolis, MN.
- Braatz, R. D., M. L. Tyler, M. Morari, F. R. Pranckh and L. Sartor (1992). Identification and cross-directional control of coating processes. *AIChE J.* **38**, 1329–1339.
- Braatz, R. D., P. M. Young, J. C. Doyle and M. Morari (1994). Computational complexity of μ calculation. *IEEE Trans. Autom. Control*, **AC-39**, 1000–1002.
- Chen, J. and J. S. Freudenberg (1990). Robust design for ill-conditioned plants with diagonal input uncertainty. In *Proc. 28th Allerton Conf. on Communication, Control, and Computing*, Monticello, IL, pp. 755–764.
- Doyle, J. C. (1982). Analysis of feedback systems with structured uncertainties. *IEE Proc., Pt D*, **129**, 242–250.
- Doyle, J. C. and C.-C. Chu (1985). Matrix interpolation and h_∞ performance bounds. In *Proc. American Control Conf.*, Boston, MA, pp. 129–134.
- Freudenberg, J. S. (1989). Analysis and design for ill-conditioned plants. Part 2: Directionally uniform weightings and an example. *Int. J. Control*, **49**, 873–903.
- Hazewinkel, M. and C. Martin (1983). Symmetric linear systems: an application of algebraic system theory. *Int. J. Control*, **37**, 1371–1384.
- Hovd, M. and S. Skogestad (1994a). Control of symmetrically interconnected plants. *Automatica*, **30**, 957–973.
- Hovd, M. and S. Skogestad (1994b). Sequential design of decentralized controllers. *Automatica*, **30**, 1601–1607.
- Hovd, M., R. D. Braatz and S. Skogestad (1996). Optimality of SVD controllers. Technical Report, Department of Chemical Engineering, Norwegian University of Science and Technology, Trondheim (available from the Internet on <http://www.kjemi.unit.no/~skoge>).
- Hung, Y. S. and A. G. J. MacFarlane (1982). *Multivariable Feedback: A Quasi-classical Approach*. Lecture Notes in Control and Information Sciences, Vol. 40, Springer-Verlag, Berlin.
- Lau, H., J. Alvarez and K. F. Jensen (1985). Synthesis of control structures by singular value analysis: dynamic

- measures of sensitivity and interaction. *AICHE J.*, **31**, 427–439.
- Laughlin, D. L., M. Morari and R. D. Braatz (1993). Robust performance of cross-directional basis-weight control in paper machines. *Automatica*, **29**, 1395–1410.
- Lee, J. H., R. D. Braatz, M. Morari and A. Packard (1995). Screening tools for robust control structure selection. *Automatica*, **31**, 229–235.
- Limebeer, D. J. N. (1991). The specification and purpose of a controller design case study. In *Proc. 30th IEEE Conference on Decision and Control*, Brighton, U.K., pp. 1579–1580.
- Lin, J. L. (1992). Control system design for robust stability and robust performance. PhD Thesis, University of Leicester, U.K.
- Lundström, P., S. Skogestad and Z.-Q. Wang (1991). Performance weight selection for h -infinity and μ -control methods. *Trans. Inst. Modeling and Control* **13**, 241–252.
- Lunze, J. (1986). Dynamics of strongly coupled symmetric composite systems. *Int. J. Control*, **44**, 1617–1640.
- Lunze, J. (1991). *Feedback Control of Large-scale Systems*. Prentice-Hall, New York.
- Martino, R. (1991). Motor-driven cams actuator flexible-lip automatic die. *Modern Plastics*, **68**, 23.
- Poola, K. and A. Tikku (1995). Robust performance against time-varying structured perturbations. *IEEE Trans. Autom. Control*, **AC-40**, 1589–1602.
- Shinskey, F. G. (1979). *Process Control Systems*, 3rd ed. McGraw Hill, New York.
- Shinskey, F. G. (1984). *Distillation Control*, 2nd ed. McGraw Hill, New York.
- Skogestad, S., M. Morari and J. C. Doyle (1988). Robust control of ill-conditioned plants: high-purity distillation. *IEEE Trans. Autom. Control*, **AC-33**, 1092–1105.
- Skogestad, S., P. Lundström and M. Hovd (1989). Control of identical parallel processes. In *Proc. AIChE Annual Meeting*, San Francisco, CA, Paper 167Ba.
- Wilhelm, R. G. Jr and M. Fjeld (1983). Control algorithms for cross directional control: the state of the art. In *Preprints of 5th IFAC/IMEKO Conf. on Instrumentation and Automation in the Paper, Rubber, Plastics, and Polymerization Industries*, Antwerp, Belgium, pp. 139–150.
- Yaniv, O. and N. Barlev (1990). Robust non iterative synthesis of ill-conditioned plants. In *Proc. American Control Conf.*, San Diego, CA, pp. 3065–3066.