


# SOUTH CHICAGO MASTERPLAN

Yu Qian Ang | Jakub Tomasz Szczesniak | Tessa Weiss | Moulshree Mittal





FINAL PRESENTATION

# CONTEXT








# CONTEXT



- Lack diversity
- Less vibrant
- Less economic opportunities
- Less accessible



# CONTEXT



# PLANNING GOALS



## SUSTAINABLE

*Energy efficient planning and design, balancing resource demands and supply (such as having buildings respond smartly to load on the grid)*

To achieve **lower EUI and embodied energy** than the average,

Stretch goal of having **net-zero operational energy**



## DIVERSE

*Economically and socially equitable, welcoming to diverse groups of people from various demographics and professions*

To create a **vibrant mixed-use district**

Affordable housing, start-ups, **innovation** district



## LIVEABLE








*A localized, self-sustaining district where people work, live, and play, but with a low carbon footprint*


To incorporate **green areas** such as parks and urban farming/gardens,

to have a car-lite district planned for **walkability**



# STREET GRID






PROTOBLOCK ► SITE ► URBAN







### Building in wood has positive effects for the environment

CO<sub>2</sub> emissions for different materials (in tonnes CO<sub>2</sub>)





Data source: InWood International Mag. Issue 55, Feb-Mar 2004



PROTOBLOCK FABRICATION



# PROTOBLOCK ONE





- Mixed use interspersed with **green spaces**
- Residential blocks with unobstructed view
- Slim tower blocks for **daylight penetration**
- Circulation spaces **encourages walking**





- Variant with **data centre**
- Allows **heat recovery** to upper storeys

# PROTObLOCK TWO



- Mixed use with **green spaces**
- Residential blocks with unobstructed view
- Slim tower blocks for **daylight penetration**
- Space within the block for community activities
- South facing facades for **potential BIPV use**
- **Green spaces** for food production



- Variant with **data centre**
- Allows **heat recovery** to upper storeys

# FLOORPLANS + LAYOUTS

## RESIDENTIAL

Typical Studio



Typical 1 Bedroom




Typical 2 Bedroom



## COMMERCIAL


Typical Meeting Room



Typical Office



Typical Retail



'Mini Central Parks'  
Carparks  
Urban farm rooftops



Ferry Terminal




Green Spaces/Farms



Main Waterfront



Carpark with  
Solar PV Rooftops




Transport Terminal





# OVERVIEW

 Retail + Community

 Residential

 Office

GFA (site): ~380,000 m<sup>2</sup>

FAR: ~2


Resi-to-Office ratio (site): 5:1

Res-to-Retail ratio (site): 3:1

Occupants (site): ~15,000

Office capacity: ~3,000 workers

Site to entire area ratio: ~1:7







Slake Shore Dr

VIEW EXPLORATION



# SECTIONS



Daylight



Energy



Renewables



Carbon



Transport




Food



Finance

# DAYLIGHT



Daylight



Energy



Renewables



Carbon



Transport




Food




Finance


# DAYLIGHT PARAMETRIC




## Variant 1



## Variant 2




# DAYLIGHT PRECINCT



**Final SDA: 64**

# ENERGY



Daylight



Energy



Renewables



Carbon



Transport





Food




Finance

# ENERGY PARAMETRIC

Variant 1



WWR 60%  
SDA: 71





Base

Advance

Office: 270 kW/m<sup>2</sup> | Office: 101 kW/m<sup>2</sup>  
Retail: 187 kW/m<sup>2</sup> | Resi: 163 kW/m<sup>2</sup>  
Resi: 372 kW/m<sup>2</sup> | Resi: 331 kW/m<sup>2</sup>

Variant 2



WWR 60%  
SDA: 91

EUI base: 276 kWh/m<sup>2</sup>  
EUI upgrade: 244 kWh/m<sup>2</sup>


# EVOLVED PROTO URBAN

41

Slate Ship Dr


Mixture of variants

Base vs Upgrade (Mean of 3 Prog Types)







# ENERGY PRECINCT



**Final EUI:**  
**214 kWh/m<sup>2</sup>**  
*(without renewables  
or heat recovery)*


# ENERGY CONSUMPTION



# DISTRICT ENERGY SYSTEM


SUPPLY SIDE

DEMAND SIDE




# DATA CENTRE

- ~3m<sup>2</sup> per server rack
- Average power consumption per rack today is around 7kW (higher density or peak demand can hit 15 kw/rack)
- Assume allocation of 2,000 server racks/proto-block (i.e 30,000 kw)



- 4 Base blocks per proto-block (up to 6500 m<sup>2</sup>)



Life Is On | Schneider Electric | DATA CENTER POWER SIZING CALCULATOR | [Twitter](#) | [LinkedIn](#) | [Facebook](#) | [Email](#) | [Info](#) | [Help](#)

### Inputs

**Servers & Storage**

Server Quantity: 10000

Server Population: 90% (1-2 CPU sockets) + 10% (4 CPU sockets) + 0% (8+ CPU sockets) = 100%

Percentage of Blade Servers: 10%

Mainframe Quantity: 1

Internal Storage: Typical

External storage: Typical

Percentage of Servers that Boot from SAN/NAS: 0%

**Design Attributes**

Power Usage Effectiveness (PUE): 1.8

Safety Margin for IT Load: 20%

### Results

**Requirements**

Data center IT Capacity Rating: 6310 kW

Utility Input Power: 11360 kW


**Allocation of Input Power**

44.46%



9.26% Networking  
3.26% External Storage  
6.52% Servers/Mainframes  
36.51% Safety Margin  
44.46% Physical Infrastructure

# WINTER

## Waste Heat Extraction



Typical Server Room CRAC Design




- Augment with heat pumps to boost 70 to 80°C sufficient for district heating purposes
- Modern heat pumps for such purposes highly efficient (COP of 3 to 5)
- In ongoing air stream, no effect on architectural or structural design



# SUMMER

## Lake Source Cooling for District Cooling & Data Centre


### Lake Michigan Temperature



- ASHRAE TC9.9 Guidelines (25°C)
- Modern optimized data centers set-point (10-15°C)
- Legacy data center chilled water set-point (6-7°C)






### LSC System






- Cold lake water pumped to heat exchanger at shore, where it absorbs some of the heat used to cool the district. Utilises gravity
- closed loop of chilled water circulating through buildings and data center will collect heat removed by air conditioning

# PV PROTOBLOCKS




# PV CARPARKS






# PROTO ENERGY

## Single Protoblock breakdown




### Monthly Energy Use/Loads (kWh)




# PROTO ENERGY

## Single Protoblock breakdown

### Monthly Energy Use/Loads (No Data Centre)







### Monthly Energy Use/Loads (With Data Centre)



■ Cooling ■ Heating ■ Lighting ■ Equipment ■ DHW ■ PV Precinct Proto ■ PV Carpark Proto


■ Cooling ■ Heating ■ Lighting ■ Equipment ■ DHW  
 ■ DC Summer ■ DC Winter ■ PV Precinct Proto ■ PV Carpark Proto

# OUTDOOR THERMAL COMFORT



UTCI (°C) range	Stress Category
above +46	extreme heat stress
+38 to +46	very strong heat stress
+32 to +38	strong heat stress
+26 to +32	moderate heat stress
+9 to +26	no thermal stress
+9 to 0	slight cold stress
0 to -13	moderate cold stress
-13 to -27	strong cold stress
-27 to -40	very strong cold stress
below -40	extreme cold stress

# TRANSPORT



Daylight



Energy



Renewables



Carbon



Transport





Food



Finance

# MACRO MOBILITY

## Public Transit to Central Chicago




Ride duration to Chicago Downtown:

- **Ferry** – 30- 40 minutes.
- **CTA bus/train** – 45 minutes to 1 hour.

# MICRO MOBILITY

Carparks


— Carpark Connections



- Car Park footprint area ~ 204000 sq.m. = 13600 car spaces
- Site Residents + Employees ~ 15000
- Entire neighbourhood Residents + Employees ~ 105,000
- Car Parking spaces required for entire urban area ~ 66500
- Car Park floors required to cater the parking needs = 5.

# MICRO MOBILITY

Within Chicago South Area



## Electric Scooter/Bike:

- Time from Carpark 1 to 2~ **1.7 min**
- Time from Carpark 1 to Ferry~ **2.3 min**
- Time from Carpark 1 to Terminal~ **3.5 min**
- Time from Ferry to Transit- **2.1 min**

## Walking



## Bike Sharing



## Terminal


## Electric Scooter Sharing



## Walking:

- Time from Carpark 1 to 2~ **5.7 min**
- Time from Carpark 1 to Ferry~ **7.8 min**
- Time from Carpark 1 to Terminal~ **11.5 min**
- Time from Ferry to Transit- **6.9 min**


# WALKABILITY




- Schools
- Restaurants
- Shopping
- Ferry Terminal
- Books
- Grocery
- Banks
- Transport Terminal
- Cafes
- Entertainment
- Fitness Centre
- Car Parks



# WALKABILITY



# FOOD PRODUCTION



Food consumption  
(t/year)



7,571

Food expenditure  
(k\$/year)





52,192



# FOOD PRODUCTION

1,900 shipping container farms equivalent  
~60,000 m2




Carbon Savings  
(vs. baseline)



1,534

tCO2eq/year



Jobs created



534

workers



Profit  
(vs. baseline)




9,541

k\$/year



# FINANCES AND PAYBACK



	Square foot (m2)	Monthly Rents (\$/m2)	Average Construction (\$/m2)	LEED Construction (\$/m2)	Average Construction Payback Period
<b>Residential</b>	242,174	29	5113	6135	15 years
<b>Commercial</b>	48,075	418	7858	9429	< 2 years
<b>Retail</b>	78,282	276	6028	7233	< 2 years

# OVERALL SCORING



Daylight




Energy




Renewables




Carbon




Transport



Food



Finance



SOUTH  
CHICAGO  
THANK YOU



# TEMPLATE PARAMETERS

	Office Base	Office Upgraded	Retail Base	Retail Upgraded	Resi. Base	Resi. Upgraded
People Density	0.05 p/m <sup>2</sup>	0.4 p/m <sup>2</sup>	0.2 p/m <sup>2</sup>	0.2 p/m <sup>2</sup>	0.03 p/m <sup>2</sup>	0.05 p/m <sup>2</sup>
Equip. Power Density	11 W/m <sup>2</sup>	6 W/m <sup>2</sup>	5 W/m <sup>2</sup>	4 W/m <sup>2</sup>	5.4 W/m <sup>2</sup>	4 W/m <sup>2</sup>
Light. Power Density	12 W/m <sup>2</sup>	8 W/m <sup>2</sup>	20 W/m <sup>2</sup>	12 W/m <sup>2</sup>	5.4 W/m <sup>2</sup>	4 W/m <sup>2</sup>
Glazing	Single Pane (5.9 UVal)	Triple Pane (0.9 UVal)	Single Pane (5.9 UVal)	Triple Pane (0.9 UVal)	Single Pane (5.9 UVal)	Triple Pane (0.7 UVal)
Occupancy Schedule	9am – 6pm	9am – 6pm	9am – 6pm	9am – 6pm	6pm-8am	6pm-8am
Heat Recovery	None	Enthalpy	None	Enthalpy	None	Enthalpy
Cooling Set Point	25C	25C	25C	25C	26C	26C
Heating Set Point	20C	18C	20C	18C	20C	20C
Cooling COP	3	3.5	3	4	3.7	4.2
Heating COP	1	1.5	1	1.5	1.25	4.2
Bouyancy Driven Flow	Off	On (Set Point 23C)	Off	On (Set Point 23C)	On	On (Set Point 23C)
Hot Water	On (Supply Temp 65)	On (Supply Temp 65)	On (Supply Temp 65)	On (Supply Temp 65)	On (Supply Temp 65)	On (Supply Temp 65)
Hot Water COP	1	3	1	3	1	4.2
Construction	Mainly Concrete Assemblies - 0.357 UVal (Roof) - 0.478 UVal (Wall)	Mainly CLT Assemblies - 0.212 UVal (Roof) - 0.338 UVal (Wall)	Mainly Concrete Assemblies - 0.318 UVal (Roof) - 0.291 UVal (Wall)	Mainly CLT Assemblies - 0.212 UVal (Roof) - 0.338 UVal (Wall)	Steel frame and concrete: - 0.357 UVal (Roof) - 1.577 Uval (Slab) - 0.361 UVal (Wall)	Steel frame/wood sliding/gypsum+insul. - 0.357 UVal (Roof) - 0.171 Uval (Slab) - 0.361 UVal (Wall)